

Certificate of Compliance

Certificate: 2219456

Master Contract: 248084

Project: 2219456

Date Issued: October 14, 2009

Issued to: Pentair Water Pool and Spa, Inc.
1620 Hawkins Ave
Sanford, NC 27330
USA

Attention: Daniel J. Hrubby

The products listed below are eligible to bear the CSA Mark shown



Issued by: K. Atkins


Authorized by: Daniel Lee
Product Group Manager

PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault circuit interrupter, open type, "Class A", Type PGF 15-30A, 120V ac, 1-pole.

Combined circuit breaker and ground fault circuit interrupter, open type, "Class A" Type PGF 15-60A, 120/240V ac, 2-pole.

APPLICABLE REQUIREMENTS

CAN/CSA- C22.2 No.	0-M91	-	General Requirements - Canadian Electrical Code, Part II
CSA Standard C22.2 No.	5-02	-	Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures
CSA Standard C22.2 No.	144.1-06	-	Ground-Fault Circuit-Interrupters
T.I.L. No	D-27-03	-	Interim Certification Requirements for Ground Fault Circuit Interrupters.

Certificate: 2219456

Project: 2219456



Master Contract: 248084

Date Issued: October 14, 2009

MARKINGS

Manufacturer's name or trademark, or CSA Master Contract Number 248084, type designation, voltage rating 40C interrupting rating, Class A, Al-Cu, 60/75C, wire size, torque information and CSA Monogram appear on a CSA Accepted paper label on the front of the device.

"On" and "Off" are moulded into case, amperes rating is moulded or permanently stamped on handle. Test button has "Test" moulded into top surface.



Supplement to Certificate of Compliance

Certificate: 2219456

Master Contract: 248084

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description		
2219456	October 14, 2009	Original Project No	Model No	Listee Model No
		160807-2219456	QPF	PGF (1 Pole)
		160807-1879967	QPF	PGF (2 Pole)