

DIVISION 23 34 36.29

COMMERCIAL, GRID-TYPE, FINNED-TUBE, GAS DOMESTIC WATER HEATERS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes copper finned-tube, gas domestic water heaters

Specifier Note: Use as needed

- B. Related Sections

- 1. Building Services Piping – Division 22 10 00
- 2. Breeching, Chimneys, and Stacks (Venting) – Division 23 51 00

1.2 REFERENCES

- A. ANSI Z21.10.3/CSA 4.3
- B. ASME, Section IV
- C. 2006 UMC, Section 1107.6
- D. ANSI/ASHRAE 15-1994, Section 8.13.6
- E. National Fuel Gas Code, NFPA 54/ANSI Z223.1
- F. I=B=R
- G. NEC
- H. ASME CSD-1, 2006

1.3 SUBMITTALS

- A. Product data sheet (including dimensions, rated capacities, shipping weights, accessories)
- B. Wiring diagram
- C. Warranty information
- D. Installation and operating instructions

1.4 QUALITY ASSURANCE

- A. Regulatory Requirements
 - 1. ANSI Z21.10.3/CSA 4.3
 - 2. Local and national air quality regulations for low NOx (0-30 PPM NOx emissions) water heaters
- B. Certifications
 - 1. CSA
 - 2. ASME HLW Stamp and National Board Listed
 - 3. ISO 9001

1.5 WARRANTY

- A. Limited one-year warranty from date of installation
- B. Limited twenty-year thermal shock warranty
- C. Limited five-year heat exchanger warranty

PART 2 - PRODUCTS

2.1 MANUFACTURER

- A. Raypak, Inc.
 - 1. Contact: 2151 Eastman Ave., Oxnard, CA 93030; Telephone: (805) 278-5300; Fax: (800) 872-9725; Web site: www.raypak.com

2. Product: MVB[®] copper finned-tube domestic water heater(s)

2.2 WATER HEATERS

A. General

1. The water heater(s) shall be fired with _____ gas at a rated input of _____ BTU/hr.
2. The water heater(s) shall be CSA tested and certified with a minimum thermal efficiency of 87 percent at full fire (88.4% at part load).
3. The water heater(s) shall be ASME inspected and stamped and National Board registered for 160 PSIG working pressure and 210°F maximum allowable temperature, complete with a Manufacturer's Data Report.
4. The water heater(s) shall have a floor loading of 185 lbs./square foot or less.

B. Heat Exchanger

1. The heat exchanger shall be of a single-bank, vertical multi-pass design and shall completely enclose the combustion chamber for maximum efficiency. The tubes shall be set vertically and shall be rolled into a powder coated, ASME water heater quality, carbon steel tube sheet.
2. The heat exchanger shall be sealed to 160 PSIG rated bronze headers with silicone "O" rings, having a temperature rating over 500°F.
3. The low water volume heat exchanger shall be explosion-proof on the water side and shall carry a twenty-year warranty against thermal shock.
4. The headers shall be secured to the tube sheet by stud bolts with flange nuts to permit inspection and maintenance without removal of external piping connections. A heavy gauge stainless steel slotted heat exchanger wrap shall ensure proper combustion gas flow across the copper-finned tubes.
5. The water heater(s) shall be capable of operating at inlet water temperatures as low as 120°F without harmful condensation.
6. The water heater(s) flue connection, combustion air opening, gas connection, water connections and electrical connections shall be located on the rear.
7. The primary heat exchanger shall have accessible water heater drain valves with hose bibs to drain the water section of the primary heat exchanger.

C. Burners

1. The combustion chamber shall be of the sealed combustion type employing the Raypak high temperature FeCrAlloy woven mesh burner, mounted in a vertical orientation.
2. The burner must be capable of firing at both a complete blue flame with maximum gas and air input as well as firing infrared when gas and air are reduced. The burner must be capable of firing at 100% of rated input when supplied with 4.0" WC of inlet gas pressure, so as to maintain service under heavy demand conditions; no exceptions.
3. The burner shall use a combustion air blower to precisely control the fuel/air mixture for maximum efficiency throughout the entire range of modulation. The combustion air blower shall operate for a pre-purge period before burner ignition and a post-purge period after burner operation to clear the combustion chamber.
4. The blower shall infinitely vary its output in response to a 4-20 mA signal supplied directly from the PID modulating temperature controller, thereby electronically and precisely adjusting the volume of air and gas supplied for combustion. Minimum fire shall be 25 percent of rated input.

D. Pilot Control System

1. The water heater(s) shall be equipped with a 100 percent safety shutdown.
2. The ignition shall be Hot Surface Ignition type with full flame rectification by remote sensing separate from the ignition source, with a single-try-for-ignition sequence, to ensure consistent operation.
3. The igniter will be located to the side of the heat exchanger to protect the device from condensation during start-up.
4. The ignition control module shall include an LED that indicates six (6) individual diagnostic flash codes.
5. An external viewing port shall be provided, permitting visual observation of burner operation.

E. Gas Train

1. The water heater(s) shall have a firing/leak test valve and pressure test valve as required.
 2. The water heater(s) shall have dual-seated main gas valve.
 3. Gas control trains shall have a redundant safety shut-off feature, main gas regulation, shut-off cock and plugged pressure tapping to meet the requirements of ANSI Z21.10.3/CSA 4.3.
- F. Water Heater Control
1. The following safety controls shall be provided:
 - a. High limit control with manual reset
 - b. Flow switch, mounted and wired
 - c. ____PSIG ASME pressure relief valve, piped by the installer to an approved drain
 - d. Temperature and pressure gauge (shipped loose)
 2. The water heater(s) shall be equipped with a PID modulating temperature controller with LCD display that incorporates an adjustable energy-saving pump control relay and is factory mounted and wired to improve system efficiency; three water sensors included.
- G. Firing Mode: Provide electronic modulating control of the gas input to the water heater.
- H. Water Heater Diagnostics
1. Provide external LED panel displaying the following water heater status/faults:
 - a. Power on – Green
 - b. Call for heat – Amber
 - c. Burner firing – Blue
 - d. Service – Red
 2. Provide internal circuit board indicating the following safety faults by LED signal:
 - a. System enabled
 - b. Manual reset high limit
 - c. Auto reset high limit (optional)
 - d. Low water cut-off (optional)
 - e. Blocked vent
 - f. Low gas pressure switch (optional)
 - g. High gas pressure switch (optional)
 - h. Air pressure
 - i. Flow switch
 - j. Ignition lock-out
 3. Provide ignition module indicating the following flash codes by LED signal:
 - a. 1 flash – low air pressure
 - b. 2 flashes – flame in the combustion chamber w/o CFH
 - c. 3 flashes – ignition lock-out (flame failure)
 - d. 4 flashes – low hot surface igniter current
 - e. 5 flashes – low 24VAC
 - f. 6 flashes – internal fault (replace module)
- I. Combustion Chamber: The combustion chamber wrapper shall be sealed to reduce standby radiation losses, reducing jacket losses and increasing unit efficiency.
- J. Cabinet
1. The corrosion resistant galvanized steel jackets shall be finished with a baked-on powder coat, which is suitable for outdoor installation, applied prior to assembly for complete coverage, and shall incorporate louvers in the outer panels to divert air past heated surfaces.
 2. The water heater(s), if located on a combustible floor, shall not require a separate combustible floor base.
 3. The water heater(s) shall connect both the combustion air and flue products through the back of the unit.

K. Water Heater Pump - Refer to Equipment Schedule

2.3 WATER HEATER OPERATING CONTROLS

- A. The water heater(s) shall feature a modulating digital controller with adjustable outdoor reset, mounted and wired.
- B. Water sensors shall be shipped loose for field-installation by installing contractor. Inlet/Outlet sensors are factory-installed. Tank sensor is loose.

2.4 DIRECT VENT

- A. The water heater(s) shall meet safety standards for direct vent equipment as noted by the 2006 Uniform Mechanical Code, section 1107.6, and ASHRAE 15-1994, section 8.13.6.

2.5 SOURCE QUALITY CONTROL

- A. The water heater(s) shall be completely assembled, wired, and fire-tested prior to shipment from the factory.
- B. The water heater(s) shall be furnished with the sales order, ASME Manufacturer's Data Report, inspection sheet, wiring diagram, rating plate and Installation and Operating Manual.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Must comply with:
 - 1. Local, state, provincial, and national codes, laws, regulations and ordinances
 - 2. National Fuel Gas Code, NFPA 54/ANSI Z223.1 – latest edition
 - 3. National Electrical Code, ANSI/NFPA 70 – latest edition
 - 4. Canada only: CAN/CGA B149 Installation Code and CSA C22.1 CEC Part I
 - 5. Manufacturer's installation instructions, including required service clearances and venting guidelines
- B. Manufacturer's representative to verify proper and complete installation.

3.2 START-UP

- A. Shall be performed by Raypak factory-trained personnel.
- B. Test during operation and adjust if necessary:
 - 1. Safeties (2.2 - F)
 - 2. Operating Controls (2.3)
 - 3. Static and full load gas supply pressure
 - 4. Gas manifold and blower air pressure
 - 5. Amp draw of blower
- C. Submit copy of start-up report to Architect and Engineer.

3.3 TRAINING

- A. Provide factory-authorized service representative to train maintenance personnel on procedures and schedules related to start-up, shut-down, troubleshooting, servicing, and preventive maintenance.
- B. Schedule training at least seven days in advance.

END OF SECTION