




## ELECTRO 50 & 100 ACTUATED BALL VALVE Installation Information

ECB-3B-0700

See accompanying BV-3A Instructions for basic valve installation

### Standard Wiring Diagram



**Opening Time:** 5 seconds  
**Closing Time:** 5 seconds  
**Duty Cycle:** 25%  
**Limit Switch:** Cam Operated, Omni Directional, SPDT  
**Housing:** NEMA 4  
1/2" NPT Connection

**Voltage:** ☐ 12 VAC      ☐ 24 VAC  
☐ 12 VDC      ☐ 24 VDC  
☐ 230 VAC